

Addendum No. 4

DATE: August 7, 2025

Project: *WHA Job No. 2025-18*
Parking Lot Improvements

In accordance with documents prepared by: *Worcester Housing Authority.*

TO: ALL BIDDERS--PROPOSERS--FIRMS

The attention of professionals submitting bids for the above Request for Quotes is called to the following addendum. The items set forth herein, whether of omission, addition, substitution, or clarifications are all to be included in and form a part of the bid submitted.

This Addendum consists of ITEM 1, which are hereby incorporated into the Bidding Documents:

QUESTIONS/CLARIFICATIONS:

ITEM NO. 1: QUESTIONS/CLARIFICATIONS:

1. Question: Do you want the cracks blown out with air or a compressor?
Response: Compressor
2. Question: How do you want the crack sealant installed – do you want it with a pressure applicator or is the inferior installation by a pouring pot or V squeegee allowed?
Response: Pressure applicator.

**FAILURE TO ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORMS
MAY BE CAUSE FOR BID REJECTION.**

END OF ADDENDUM NO. 4