

## Addendum No. 1

DATE: June 4, 2024

Project: *BFI Job No. 2024-14*  
**Lewis Street Paving**

In accordance with documents prepared by: *Building Futures Inc.*

TO: ALL BIDDERS--PROPOSERS--FIRMS

This Addendum No. 1 modifies the original Request for Quotes, dated May2024. Acknowledge receipt of this Addendum in the space provided on the ACCEPTANCE OF CONTRACT TERMS. Failure to do so may result in proposal disqualification.

The attention of professionals submitting bids for the above Request for Quotes is called to the following addendum. The items set forth herein, whether of omission, addition, substitution, or clarifications are all to be included in and form a part of the bid submitted.

This Addendum consists of ITEMS 1, which are hereby incorporated into the Bidding Documents:

### **QUESTIONS/CLARIFICATIONS:**

#### **ITEM NO. 1:**

1. Question: What is the thickness of binder and top for the asphalt?  
Response: Please provide 1-1/2" Top Course and 2-1/2" Binder Course.

**FAILURE TO ACKNOWLEDGE THIS ADDENDUM ON YOUR PROPOSAL FORMS  
MAY BE CAUSE FOR PROPOSAL REJECTION.**

**END OF ADDENDUM NO. 1**